



Utility Licence Annual Report 2024-25

Licence utility:	Evoenergy
Utility service:	gas distribution
Number of parts to report:	6

Reporting period: **1 July 2024 to 30 June 2025**

Submission date: **by 1 October 2025**

Submit completed report to: **icrc@act.gov.au**



Please submit the completed report in MS excel format.

Parts to report

[Part A — Utilities Act](#)

Part B — Consumer Protection Code

[B1 — Customer Protection](#)

[B2 — Guaranteed Service Levels](#)

[B3 — Rebates paid against guaranteed service levels](#)

[Part D — Utility licence conditions](#)

[Part E — Climate Change and Greenhouse Gas Reduction Regulation](#)

Providing data and information to the Commission

Please read the **Utility Licence Annual Report Guideline** for a more detailed instructions on providing relevant and quality information to the Commission.

- All responses provided should only relate to services provided in the ACT. In the event the licensee is unable to disaggregate ACT services from other jurisdictions, the licensee must provide a statement detailing: area that the dataset covers, brief explanation why data cannot be disaggregated, additional information that may assist the Commission in understanding the approximate percentage of services that are provided in the ACT from the dataset.
- All licensed utilities must provide information and data in the report that are within the reporting period. Data must be provided even if a nil (zero) figure is recorded.
- If the licensee is not able to provide the data or answer a question required in the report, the licensee should indicate 'not available' and provide supplementary information detailing why the information is not available and whether (and in what timeframe) it intends to collect this data.
- In most cases a response of 'yes', 'no', 'not applicable' or a figure will suffice. An explanatory statement or supplementary information (e.g. copies of policies or procedures or a link to material on the internet) maybe required.

- Where data is not available the licensee must provide other data that could serve a similar purpose as the data requested (i.e. data that could equally indicate the level of licensee compliance and identify possible causes of non-compliance). Such data should be clearly identified in the report together with an explanation of the alternative taken.
- The licensee should provide commentary where there is a need to explain key factors relevant to the level of, and trends in, their performance. If the licensee response represents a significant variation in the data from the previous reporting period, additional information is to be provided on the cause(s) of the variation. Any supplementary information can be provided in the comments column, or in an attachment. Where applicable, include measures or actions to be put in place to address or rectify the reported variation. All comments must be put in the comment section box.

Part A — Utilities Act

Ref	Reporting requirements	Response	Additional comments
Our tracking number		Answer n/a if the data requested is not available. Answer "0" if data recorded is nil or zero Data must relate only to the 2024-25 reporting period unless specified otherwise.	Please provide information that you feel is relevant and will assist us in our assessment such as an explanation or a reason/s for significant variances from the previous year.
Notice to landholders to undertake network operations (Section 109)			
A102	Number of times the licensee failed to give the landholder at least seven days notice of a proposed network operation.	0	
Network operations affecting heritage significance (Section 110A)			
A106	Number of notices given under sections 109 and 110 that may have affected a place or object of heritage significance under section 110A.	0	
A107	Number of notices under section 110A where the licensee failed to provide copies to the heritage council at least seven days before the network operation.	0	
Removal of utility's property and waste (Section 112)			
A111	Number of network operations where the licensee failed to remove as soon as practicable from the land, for which it was not the landholder, items listed in section 112(1).	0	

Authorised persons (Division 7.4)

A201	Were all persons authorised under section 114 (Authorised Persons) issues with photographic identity cards?		Yes
A202	Are authorised persons made aware of their obligations and entry restrictions under the Utilities Act?		Yes
A202(b)	Provide details of any induction or special training to authorised persons to educate them about their obligations and entry restrictions under the Utilities Act. Please include whether the training is provided on a regular or ad hoc basis.		All new starters complete induction training where their obligations and entry restrictions under the Utilities ACT is communicated.

Continuity of utility services - non payment of customer debt (Section 179)

This section applies to a complaint about the actual or potential withdrawal of a utility service because of a failure to pay a customer debt in relation to residential premises.

A203	Number of written directions received from the ACAT under section 179(2).	0	
------	---	---	--

Discharge of customer debt (Section 180)

A204	Number of written declarations received from the ACAT under section 180(1).	0	
------	---	---	--

Payment for loss or damage (Section 181)

A205	Number of written directions received from the ACAT under section 181(1) to pay a stated amount to a complainant for a loss or damage.	0	
A205(a)	Provide details of each direction including stated action/s and the licensee's compliance with the direction.	N/A	

Community service obligations (Part 13)

The purpose of Part 13 of the Act is: (a) to oblige utilities to provide utility services in accordance with relevant Government programs, for example, for community services, the environment or other social issues; and (b) to achieve that results by agreement with particular utilities or; where agreement is not reached, by directions under part 13 of the Act; and (c) to provide utilities with a reasonable recompense for the provision of services in accordance with such directions.

A206	Number of directions received under section 221 from the minister responsible for a government program that required the licensee to provide utility services in accordance with the relevant government program.	0	
A207	Provide details of each direction including stated action/s and the licensee's compliance with the direction. Provide a summary with respect to the relevant government program.	N/A	
A208	Provide details for each direction of the determination of costs provided under sections 222, 223 and 219(c).	N/A	

END OF A1

Part B — Consumer Protection Code

B1 — Customer Protection

Ref Our tracking number	Reporting requirements	Response Answer n/a if the data requested is not available. Answer "0" if data recorded is nil or zero. Data must relate only to the 2024-25 reporting period unless specified otherwise.	Additional comments Please provide any information that you feel is relevant to support us in our assessment such as reason/s for non-compliance and actions taken to rectify the non-compliance and minimise future occurrences. When applicable, please also provide an explanation or a reason/s for significant variances from the previous year.
Complaints procedures (6.1 and 6.2)			
B101	Does the licensee's complaint handling procedures address all requirements of clause 6.1 of the Code?	Yes	
B101(a)	Provide a copy (or a link to a copy) of the utility's complaint handling procedures	Complaints and dispute resolution	
B102	Which version of the Australian Standard does your complaints handling policy and procedures comply with?	AS ISO 10002:2014	
Addressing complaints (6.3)			
B103	How and when are customers or consumers advised of the utility's complaints handling procedures?	"Customers are advised in the Customer Charter which is sent to all new customers. The Customer Charter for gas markets is also available on the Evoenergy website.	
B104	How and when are customers or consumers advised of their right to refer a complaint to the ACAT?	"When a complaint is acknowledged in writing, an information sheet is also provided which includes ACAT contact details. ACAT contact details are also provided as part of written responses where complainants are not satisfied with the response. ACAT contact information is given verbally for telephone complaints where the customer is not satisfied with the response"	
Utility to keep records (6.4)			
B105	Are records of complaints made by a customer or consumer kept for at least 12 months after the complaint is resolved?	All complaints are logged on our CRM system which are maintained ongoing	
Number of complaints			
B106	Total number of complaints received	54	
Breakdown of complaints per category			
Ref	Complaint category	Number of complaints	Additional comments Please provide information that you feel is relevant to assists us in our assessment such as reason/s for significant variances from the previous year. When applicable, please also include actions taken to address and minimise customer complaints.
B106(a)	Asbestos	0	
B106(b)	Abolishment	0	
B106(c)	Address details	0	
B106(d)	Billing	23	There has been a 47% reduction in compliants received this year. This may be the result of more issues being resolved by the customers retailer and some issues being categorised as reading issues.
B106(e)	Contractor behaviour	0	
B106(f)	Customer service	3	This is in line with the complaints reported in last year.
B106(g)	Damage	0	
B106(h)	Inconvenience, detriment or damage to landholders' property resulting from network operations. Section 108	2	1. Customers stormwater was impacted when the gas was connected to the poperty. The gas was connected on 13 August 2001. 2. The customer claimed Meter Reader damaged gate when entering propety.
B106(i)	Meter	6	This is in line with the complaints reported in last year.

B106(j)	New connection	0	
B106(k)	Reading	10	This is a 400% increase on last year. This is the result of some billing complaints being categorised as issues with the estimations of customers accounts.
B106(l)	Recoverable works	0	
B106(m)	Restoration	0	
B106(n)	Supply	0	
B106(o)	Carrying out operations in urgent circumstances under section 109(5).	0	
B106(p)	Operations undertaken pursuant to s 110A(2).	0	
B106(q)	Failure to give seven days notice to other public utilities before performing network operations on their land that potentially affected network facilities under the care and management of those utilities. Section 111	0	
B106(r)	Carrying out network operations in urgent circumstances under section 111(6).	0	
B106(s)	Failure to remove as soon as practicable from the land for which it was not the landholder, any items listed in section 112(1).	0	
B106(t)	Failure to ensure, as soon as practicable, that the land was restored to a condition that was similar to its condition before the operations began. Section 113	0	
B106(u)	Gas Leak	2	This is in line with the complaints reported in last year.
B106(v)	Reconnection	3	This is in line with the complaints reported in last year.
B106(w)	Meter relocation	0	
B106(x)	Other (please specify)	5	Disconnection - 3 Claim - 1 Transfer - 1

Summary of Consumer and Utility Rights (Clause 9)

B107

Was the licensee compliant with all the requirements in clause 9.3?

Yes

B108

Provide a copy of the licensee’s statement summarising the rights of a consumer and the licensee under the Utilities Act, the Consumer Protection Code and the relevant customer contract.

This is contained on the website

[Your Rights & Obligations](#)

B109

What languages is the summary available in?

Hindi, Simplified Chinese, Traditional Chinese, Spanish, and Vietnamese. These languages were based upon ABS data for the ACT: 2016 Census Data for the top 5 most spoken language in the Territory other than

Life support (Clause 10)

B110

Number of instances where the licensee failed to provide at least 4 business days’ notice of a planned interruption to a registered life support equipment supply address.

0

B110(a)

Please give details on every instance where you failed to provide at least 4 business days’ notice of a planned interruption to a registered life support equipment supply address. Also, please provide reason for the non-compliance, effect to the customer with registered life support and any rectification actions you have taken.

☒ Nothing to report

Reference code	Date of planned interruption	Duration of planned interruption	Reason for the non-compliance	What was the effect to the customer with registered life support?	Was the incident reported to the AER?	Remediation
Your reference code	enter as dd/mm/yyyy	enter as hours:minutes	provide a reason(s) for not giving notice within the required timeframe	We will use your response to assess whether the effect of the incident to the customer is serious or not.	Y/N	provide details of actions taken to rectify the non-compliance and to minimise future occurrences

Note: Press tab on your keyboard to start a new line.

END OF B1

Part B — Consumer Protection Code**B2 — Guaranteed Service Levels**

Ref Our tracking number	Reporting requirements	Response Answer n/a if the data requested is not available. Answer "0" if data recorded is nil or zero.	Additional comments Please provide any information that you feel is relevant to support us in our assessment such as reason/s for non-compliance and actions taken to rectify the non-compliance and minimise future occurrences.															
		Data must relate only to the 2024-25 reporting period unless specified otherwise.	When applicable, please also provide an explanation or a reason/s for significant variances from the previous year.															
Obligation to pay rebate for non-compliance (Clause 11)																		
B111	Number of GSL rebate payments made	3																
B111(a)	Amount of GSL rebate payments made	\$500																
B112	Number of breaches of GSL's where rebates have not been paid	\$0																
B113	In relation to B112, why have the GSL payment not been made?	N/A																
B114	In relation to B112, how are customers advised that a GSL payment has not been made?	N/A																
B115	Number of GSL rebate payments made in the same or next billing quarter to the quarter the obligation to pay the GSL rebate occurred	\$3																
B116	Number of GSL rebate payments made more than one billing quarter after the quarter the obligation to pay the GSL rebate occurred	\$0																
B116(a)	In relation to B116, why were the GSL rebate payments made more than one billing quarter after the quarter the obligation to pay the GSL rebate occurred	N/A																
Customer connection times (Guaranteed Service Level 1)																		
B201	Number of customer connections not made within the required timeframe specified in the Consumer Protection Code.	1	GSL1 was paid to customer for a re-connection (not a new connection) that was not completed within required timeframe.															
B202	What percentage does this represent of total connections?	0.04%																
Wrongful disconnection (Guaranteed Service Level 2)																		
B203	Number of wrongful disconnections.	2																
B203(a)	Please give details on every instance of a wrongful disconnection. Also, please provide reason for failure to meet the required service level and actions taken to rectify the non-compliance and minimise future occurrences.																	
☐ Nothing to report Your incident reference number <table><thead><tr><th>Date customer disconnected <i>enter as d -mm-yy</i></th><th>Date customer reconnected <i>enter as dd -mm-yy</i></th><th>Reason for failure to meet the required service level <i>provide a reason(s) for the wrongful disconnection</i></th><th>What was the effect to the customer? <i>We will use your response to assess whether the effect of the incident to the customer is serious or not.</i></th><th>Remediation <i>provide details of actions taken to rectify the non-compliance and to minimise future occurrences</i></th></tr></thead><tbody><tr><td>31/10/2024</td><td>1/11/2024</td><td>Human Error: The technician disconnected the meter at the incorrect address.</td><td>The customer was off supply for roughly 23 hours.</td><td>- The technician was brought in for an incident review. - The incident was addressed at the toolbox talk to reinforce re-starting the 2-step verification process before carrying out any works if the technician has to temporarily leave the site after carrying out the initial 2-step process.</td></tr><tr><td>15/10/2024</td><td>16/10/2024</td><td>Cross Meter: The technician disconnected the meter at the incorrect address.</td><td>The customer was off supply for around 1 day</td><td>The meter correction has been completed and both retailers notified of the changes.</td></tr></tbody></table>				Date customer disconnected <i>enter as d -mm-yy</i>	Date customer reconnected <i>enter as dd -mm-yy</i>	Reason for failure to meet the required service level <i>provide a reason(s) for the wrongful disconnection</i>	What was the effect to the customer? <i>We will use your response to assess whether the effect of the incident to the customer is serious or not.</i>	Remediation <i>provide details of actions taken to rectify the non-compliance and to minimise future occurrences</i>	31/10/2024	1/11/2024	Human Error: The technician disconnected the meter at the incorrect address.	The customer was off supply for roughly 23 hours.	- The technician was brought in for an incident review. - The incident was addressed at the toolbox talk to reinforce re-starting the 2-step verification process before carrying out any works if the technician has to temporarily leave the site after carrying out the initial 2-step process.	15/10/2024	16/10/2024	Cross Meter: The technician disconnected the meter at the incorrect address.	The customer was off supply for around 1 day	The meter correction has been completed and both retailers notified of the changes.
Date customer disconnected <i>enter as d -mm-yy</i>	Date customer reconnected <i>enter as dd -mm-yy</i>	Reason for failure to meet the required service level <i>provide a reason(s) for the wrongful disconnection</i>	What was the effect to the customer? <i>We will use your response to assess whether the effect of the incident to the customer is serious or not.</i>	Remediation <i>provide details of actions taken to rectify the non-compliance and to minimise future occurrences</i>														
31/10/2024	1/11/2024	Human Error: The technician disconnected the meter at the incorrect address.	The customer was off supply for roughly 23 hours.	- The technician was brought in for an incident review. - The incident was addressed at the toolbox talk to reinforce re-starting the 2-step verification process before carrying out any works if the technician has to temporarily leave the site after carrying out the initial 2-step process.														
15/10/2024	16/10/2024	Cross Meter: The technician disconnected the meter at the incorrect address.	The customer was off supply for around 1 day	The meter correction has been completed and both retailers notified of the changes.														
Responding to complaints (Guaranteed Service Level 3)																		
B204	Number of complaints not responded to within 20 business days.	0																
Planned interruptions to utility services (Guaranteed Service level 4)																		
B205	Number of planned interruptions to services.	1427	Planned/aged meter replacement program volumes based on end of life meters are a key driver for annual volume fluctuations															
B206	Number of premises that were not provided with 4 business days' notice of a planned interruption.	0																
B206(a)	Please give details on every instance where you did not give at least 4 business days' notice of a planned interruption. Also, please provide reason for failure to meet the required service level and actions taken to rectify the non-compliance and minimise future occurrences.																	
☐ Nothing to report																		

Reference code <i>Your reference code</i>	Date of planned interruption <i>enter as dd/mm/yyyy</i>	Number of affected premises	Number of premises not notified	Reason for failure to meet the required service level <i>provide a reason(s) for the wrongful disconnection</i>	Remediation <i>provide details of actions taken to rectify the non-compliance and to minimise future occurrences</i>

Unplanned sustained interruptions to utility services (Guaranteed Service level 5)

B207	Number of unplanned sustained interruptions that lasted longer than 12 hours.	30	RY25 - All unplanned sustained interruptions >12 hours were for No Supply issues on the inlet service to individual properties where the priority was downgraded to "24 hours" or "7 days" via the Jemena Response Centre triage.
-------------	---	----	---

B207(a) Please give details on every instance where an unplanned sustained interruption lasted longer than 12 hours. Also, please provide reason for failure to meet the required service level and actions taken to rectify the non-compliance and minimise future occurrences.

 Event data report Your reference code	Date <i>enter as dd/mm/yyyy</i>	Duration of unplanned sustained interruption <i>enter as hours:minutes</i>	Number of premises affected	Number of premises that experienced an unplanned sustained interruption that lasted 12 hours or longer	Did this event occur on a Major Event day? <i>(as classified under the AER's distribution reliability measures)</i> Y/N	Reason for failure to meet the required service level <i>provide a reason(s) for the wrongful disconnection</i>	Remediation <i>provide details of actions taken to rectify the non-compliance and to minimise future occurrences</i>
Z403060890	7/01/2024	28:14	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technician attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403066314	7/05/2024	18:19	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technician attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403074339	15/07/2024	21:41	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technician attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.

Z403077385	18/07/2024	17:01	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403081112	22/07/2024	21:01	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403088603	29/07/2024	15:05	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403086830	29/07/2024	24:02	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403090256	31/07/2024	18:04	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403090304	31/07/2024	18:29	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.

Z403147387	10/04/2024	15:49	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403154860	10/11/2024	13:46	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403159152	16/10/2024	18:32	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403169115	24/10/2024	17:56	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403183174	11/11/2024	43:29	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403184763	13/11/2024	22:50	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.

Z403191050	20/11/2024	14:25	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403191323	21/11/2024	22:38	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403204966	12/06/2024	16:49	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403205287	12/08/2024	17:58	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403226139	13/01/2025	20:21	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403257539	20/02/2025	18:05	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.

Z403263914	3/03/2025	14:20	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403281984	31/03/2025	22:29	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403285102	4/03/2025	20:19	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403302868	5/02/2025	17:00	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403309463	5/09/2025	17:05	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403311164	13/05/2025	22:01	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.

Z403323293	28/05/2025	21:38	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403330245	6/04/2025	18:19	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.
Z403331491	6/05/2025	15:10	1	1	N	Job Priority was downgraded to 7 days. This was not a wrongful disconnection it was a "No Supply" issue on the inlet service that was reported by the customer to Jemena. The main drivers have been found to be regulator OPSO tripping, meter control valve turned off, appliance relight required and customer/customer piping system related issues.	Gas Supply Technican attended site and rectified "No Supply" issue based on investigation of issue and problem solving solution, for example, reset tripped OPSO, rreplaced faulty regulator, turned on meter control valve, relit customer appliance pilot.

Unplanned sustained interruption means an unplanned interruption to a utility service that has a duration longer than three minutes.

For reference, see Dictionary in the Consumer Protection Code 2020.

Cumulative duration of interruptions to utility services (Guaranteed Service level 6)

B208	Number of properties that experienced 20 hours of interruptions during the reporting year	15	RY25 Commentary: Planned Interruptions = 0 properties. RY25 Unplanned Interruptions = 15 properties.
B209	Number of properties that experienced 30 hours of interruptions during the reporting year	3	RY25 Commentary: Planned Interruptions = 0 properties. RY25 Unplanned Interruptions = 3 properties.
B210	Number of properties that experienced 60 hours of interruptions during the reporting year	0	RY25 Commentary: Planned Interruptions = 0 properties. RY25 Unplanned Interruptions = 0 properties.
B210(a)	Provide details of actions taken to minimise future interruptions for the customers who have experienced 20 hours or more of interruptions	Actions taken can differ for each interrupton. Gas Supply Technicans attend sites for "No Supply" issues reported to the Jemena Control Room. Based on investigation of each unique job the issue is either resolved immediately or the repair prioritised based on severity.	RY25 Comment - for RY24 Cumulative interruptions to utility services was previously assumed to be "Planned". For RY25 all "Planned" and "Unplanned" interruptions to utility services have been included for the Cumulative duration volumes counts for B208 to B210.

Frequency of Interruptions (Guaranteed Service level 7)

B211	Number of customers that experienced more than 9 sustained interruptions during the reporting year	0	RY25 Commentary: Planned Interruptions = 0 properties. RY25 Unplanned Interruptions = 0 properties.
------	--	---	---

Response time to notification of problem or concern (Guaranteed Service Level 8)

B212	Total number of notifications received related to damage to, or a fault or problem with the utility network.	2492	Includes all Gas Escapes, Third Party Hits, Poor Supply and No Supply Orders
B213	Number of notifications related to damage to, or a fault or problem with the utility network likely to affect public health, or caused or potentially caused, substantial damage or harm to a person or property (priority 1).	567	Includes Jemena Priority B (4 hours) volume 22.9.25 - This is consistent with previous years Basis of Preparation. Volumes represent all calls made by members of public or third parties including orders where no issue was found during the field visit i.e. "No Issue Report-in Codes". Priority 1 = Jemena Priority B (4 Hours) volume, Priority 2 = Jemena Priority C (24 Hours) volume. Data reported is similar to RY24 volumes.
B214	Number of priority 1 notifications not responded to within six hours.	0	Jemena use "respond to the call" as an initial response meeting the 6 hours and then resolve in accordance with our priority which meeting the requirements of the Code
B214(a)	Please give details on each instance where a priority 1 notification was not responded to within six hours. Also, please provide reason for failure to meet the required service level and actions taken to rectify the non-compliance and minimise future occurrences.		

Reference code <i>Your reference code</i>		Date <i>enter as dd/mm/yyyy</i>	How long before you responded? <i>enter as hours:minutes</i>	Suburb/s or area affected	Number of customers affected	Reason for failure to meet the required service level <i>provide a reason(s) for the wrongful disconnection</i>	What was the effect to the customer? <i>We will assess your response as to whether the effect of the incident to the customer is serious or not.</i>	Remediation <i>provide details of actions taken to rectify the non-compliance and to minimise future occurrences</i>
Note: Press tab on your keyboard to start a new line.								
B214(b)	Number of priority 1 notifications that were not resolved in the time specified to the customer	N/A			Timeframes are not generally specified to customer so this cannot be measured			
B215	Number of notifications related to other problems or concerns that were not likely to affect public health, or cause or potentially cause substantial damage or harm to a person or property (priority 2).	573			Includes Jemena Priority C (24 hours) volume 22.9.25 - This is consistent with previous years Basis of Preparation. Volumes represent all calls made by members of public or third parties including orders where no issue was found during the field visit i.e. "No Issue Report-in Codes". Priority 1 = Jemena Priority B (4 Hours) volume, Priority 2 = Jemena Priority C (24 Hours) volume. <u>Data reported is similar to RY24 volumes.</u>			
B216	Number of priority 2 notifications not responded to within 48 hours.	0			Jemena use respond to the call as an initial response meeting the 48 hours and then resolve in accordance with our priority which meeting the requirements of the Code			
B217	Number of priority 2 notifications that were not resolved in the time specified in the response to the customer.	NA			Timeframes are not generally specified to customer so this cannot be measured			

END OF B2

Part B — Consumer Protection Code

B3— Rebates paid against guaranteed service levels

Answer n/a if the data requested is not available. Answer "0" if data recorded is nil or zero.

			Number of times GSL was not met in 2024 ²⁰²⁵	Number of GSLs paid in 2024 ²⁰²⁵	Value of GSLs paid in 2024 ²⁰²⁵	Additional comments
Reporting year	Ref	Subject of the service level				
2024-25	GSL-1	Customer connection times	1	1	\$300	
2024-25	GSL-2	Wrongful disconnection	2	2	\$200	
2024-25	GSL-3	Responding to complaints	0	0	0	
2024-25	GSL-4	Notice of planned interruption to services	0	0	0	
2024-25	GSL-5	Duration of interruption (single)	0	0	0	
2024-25	GSL-6	Cumulative duration of interruptions	0	0	0	
2024-25	GSL-7	Frequency of interruptions	0	0	0	
2024-25	GSL-8	Response time to network problems or concern	0	0	0	
Total			3	3	\$ 500	

Part D — Utility licence conditions

Ref	Reporting requirements	Response	Additional comments
Our tracking number		Answer n/a if the data requested is not available. Answer "0" if data recorded is nil or zero. Data must relate only to the 2024–25 reporting period unless specified otherwise.	
Licensee to notify ICRC of any material breaches (Clause 8.2)			
D101	Number of material breaches of the licensee's licence or any applicable law, code of practice, directions and guidelines.	0	No Material Breaches
D101(a)	Please provide the dates for each material breach and the type of breach	N/A	
D101(b)	Was the Commission notified of the breaches? NB - Immediate reporting applies to material breaches, see the ICRC Material Breach Guideline 2021	N/A	
Licensee to provide statement on any non-compliance (Clause 8.3)			
D102	Number of non-compliances with any of the licensee's obligations under clause 6.2 of its licence to comply with the Utilities Act, relevant Industry Codes, relevant Technical Codes, any directions given by the ICRC or any applicable ring-fencing requirements	0	Evoenergy proactively monitors & reports on compliance matters & incidents involving non-compliance in line with regulatory obligations under the Utilities Act, relevant industry & technical codes. Evoenergy have a Ring-fencing waiver valid until 2029.
D102(a)	Provide details of each non-compliance, including actions taken to rectify or minimise the effect of the non-compliance.	N/A	
D102(b)	Was the Commission notified of the non-compliances?	N/A	

Availability of Utility Licence Annual Report (Clause 8.5)		
D103	Was a summary of the 'Utility Licence Annual Report' (ULAR) for 2023-24 made publicly available by the licensee?	Yes The ICRC ULAR is published on the Evoenergy public website
D103(a)	Please provide the link to the ULAR summary.	Evoenergy Gas ULAR 2023-24 Annual Report to ICRC for Utility Licence (ULAR) 2023-24 (Gas)
D103(b)	Please confirm that a summary of the 2024–25 ULAR will be published before 30 November this year	Yes Evoenergy will publish the ICRC ULAR on its public website by 30 November 2025
Operation and compliance audits (Clause 8.6)		
D104	When was the last time the licensee reviewed its data collection and reporting process?	Feb-25
D105	How often does the licensee audits or review its data collection and reporting process?	Annually
Technical and prudential criteria (Clause 9)		
Click here for a copy of the Commission's guidelines on prudential and technical criteria		
D106	Please provide a summary of details of the licensee's financial and technical capacity for 2024–25 which show it can continue to provide the services authorised in the licence.	Please refer to attached document ActewAGL Distribution SPFR (2025) Please note this document is confidential and only for purpose of the commissioners use.
Charge and assignment (Clause 11)		
D107	Were there any significant transfers in shareholdings (involving more than 50% of the shares) or changes in ownership in 2024–25?	No
D107 (a)	If yes, please provide details.	N/A
Record keeping (Clause 14)		
D108	Has the licensee kept or caused to be kept, comprehensive records in accordance with Commission's requirements under the Utilities Act?	Yes Evoenergy keeps records in line with its regulatory obligations.
Emergency telephone service (Schedule 1: Clause 1)		

D109	Did the licensee maintain a 24 hour emergency telephone service that was accessible to the public every day of the year and able to receive reports of network emergencies?	Yes	
D109(a)	How are customers and the public informed of the service?	The emergency telephone number (131 909) is displayed in the public telephone directory and on Evoenergy's website as well as being listed on customer invoices issued by the retailers.	
Compliance with the National Gas (ACT) Act 2008 (Schedule 1: Clause 2)			
D110	Does the licensee has network operation standards in place that comply with:	Yes	
	· the National Gas (ACT) Act 2008; or	Yes	
	· any other legislation in force in the Territory that relates to the provision of services to gas suppliers necessary to facilitate the operation of a competitive gas retail market in the Territory.	Yes	
Environmental requirements (Schedule 1: Clause 3)			
D111	Are the licensee's environmental management policies and practices in line with the current APGA Code of Environmental Practice and the Australian Pipeline Industry Code of Practice for Pipeline Construction?	Yes	
D111 (a)	If no, describe how they differ and why.		
Additional reporting (Schedule 1: Clause 4) — Total pipeline length by pressure classes at 30 June 2024(km)			
D112	Medium pressure	3968	
D113	High pressure	256	

D114	Please provide an update of general technical description (in total) as provided in the licence application to the Commission.	Refer to Attachment A.	Attachment A reflects the ACT based assets as detailed in Appendix A of the 2025 Evoenergy ACT Natural Gas Networks SAOP (GAS-999-PA-HSE-001)
Customer numbers			
D115	Total number of residential customers supplied in the reporting year	133,139	Residential connected sites in the ACT as at 30 June 2025 (ie excludes disconnected sites).
D116	Total number of non-residential customers supplied in the reporting year	2,630	Non-residential connected sites in the ACT as at 30 June 2025 (ie excludes disconnected sites).

END OF D1

Part E — Climate Change and Greenhouse Gas Reduction Regulation

Ref	Reporting requirements	Response	Additional comments
Our tracking	Answer n/a if the data requested is not available. Answer "0" if data recorded is nil or zero. Data must relate only to the 2024-25 reporting period unless specified otherwise.		

Licensee to notify ICRC of any new gas connections from 8 December 2023 (Clause 15)

E101	Total number of new gas connections provided from 1 July	395	Refer to the following table for individual details
------	--	-----	---

E101(a) Please provide the details of each new gas connection provided from 8 December 2023. Please provide information as much as you can for each response.

Please tick **'Nothing to report'** if you have no new gas connection to report.

☐ Nothing to report

Date gas connection application was received <i>Enter as dd/mm/yy</i>	Date gas connection was provided <i>Enter as dd/mm/yyyy</i>	Is the gas connection a new connection to the premises? <i>Answer Yes or No</i>	Does the gas connection alter an existing connection resulting in an additional point of gas supply to the premises or other premises? <i>Answer Yes or No</i>	Does the gas connection replace of reinstate an existing connection to the premise? <i>Answer Yes or No</i>	Division, district and zone where the premise is located	Is the connection an exempt new connection? <i>Answer Yes or No. Provide type of exemption if answered Yes.</i>	Class of each building supplied by the new connection	Type of connection	Capacity of gas meter (maximum delivery pressure kPa)
AS above - Andrew Moore									
1 12/08/2023	4/10/2025	YES	NO	NO	CF: ARANDA / BELCONNEN	YES Development application lodged or made before 2 March 2024	6	Commercial	2902 MJ/hr - 2.75kpa
2 29/01/2024	7/09/2024	YES	NO	NO	CZ3: CONDOR / TUGGERANONG	YES Building approval issued before 2 March 2024	6	Commercial	608 MJ/hr - 5kpa
3 26/02/2024	29/07/2024	YES	NO	NO	CZ2: BRADON / CANBERRA CENTRAL	YES Development application lodged or made before 2 March 2024	6	Commercial	2520 MJ/hr - 5kpa
4 7/02/2024	7/12/2024	YES	NO	NO	RZ1: WRIGHT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	6	Commercial	610 MJ/hr - 5kpa
5 22/06/2024	26/09/2024	YES	NO	NO	CZ3: BRADON / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	6	Commercial	1107 MJ/hr - 5kpa
6 23/08/2024	29/08/2024	YES	NO	NO	CZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2 March 2024	6	Commercial	900 MJ/hr - 5kpa
7 23/08/2024	29/08/2024	YES	NO	NO	CZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2 March 2024	6	Commercial	900 MJ/hr - 5kpa
8 23/08/2024	29/08/2024	YES	NO	NO	CZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2 March 2024	6	Commercial	800 MJ/hr - 5kpa
9 9/11/2024	28/10/2024	YES	NO	NO	CZ3: BELCONNEN / BELCONNEN	YES Building approval issued before 2 March 2024	6	Commercial	1070 MJ/hr - 5kpa
10 9/11/2024	10/04/2024	YES	NO	NO	CZ3: BELCONNEN / BELCONNEN	YES Building approval issued before 2 March 2024	6	Commercial	770 MJ/hr - 5kpa
11 9/11/2024	10/04/2024	YES	NO	NO	CZ3: BELCONNEN / BELCONNEN	YES Building approval issued before 2 March 2024	6	Commercial	750 MJ/hr - 5kpa
12 20/09/2024	10/04/2024	YES	NO	NO	CZ3: BELCONNEN / BELCONNEN	YES Building approval issued before 2 March 2024	6	Commercial	650 MJ/hr - 5kpa
13 10/04/2024	13/11/2024	YES	NO	NO	CZ2: PHILLIP / WODEN VALLEY	YES Development application lodged or made before 2 March 2024	6	Commercial	1720 MJ/hr - 5kpa
14 19/11/2024	12/03/2024	YES	NO	NO	CZ2: BELCONNEN/ BELCONNEN	YES Development application lodged or made before 2 March 2024	6	Commercial	900 MJ/hr - 5kpa
15 19/12/2024	1/10/2025	YES	NO	NO	NUZ1: BEARD / JERRABOMBERRA	YES Building approval issued before 2 March 2024	6	Commercial	400 MJ/hr -2.75kpa
16 23/12/2024	15/01/2025	YES	NO	NO	CZ5: BRUCE / BELCONNEN	YES Development application lodged or made before 2 March 2024	6	Commercial	337 MJ/hr - 2.75kpa
17 1/08/2025	29/01/2025	YES	NO	NO	IZ2: FYSHWICK / CANBERRA CENTRAL	YES Development application lodged or made before 2 March 2024	6	Commercial	2000 MJ/hr -5kpa
18 17/03/2025	14/03/2025	YES	NO	NO	CZ3: DICKSON / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	6	Commercial	190MJ/hr -2.75kpa
19 7/08/2024	29/08/2024	YES	NO	NO	DES: BARTON / CANBERRA CENTRAL	YES - NCA Land	6	Commercial	4640MJ/hr -5kpa
20 27/03/2024	29/07/2024	YES	NO	NO	CZ2: PHILLIP / WODEN VALLEY	YES Development application lodged or made before 2 March 2024	6	Commercial	320MJ/hr -2.75kpa
21 7/04/2024	30/05/2025	YES	NO	NO	CF: DEAKIN / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320MJ/hr -2.75kpa
22 22/04/2025	13/05/2025	YES	NO	NO	RZ2: WEETANGERA / BELCONNEN	YES Development application lodged or made before 2 March 2024	1	NEW HOMES	320MJ/hr -2.75kpa

23	22/04/2025	13/05/2025	YES	NO	NO	RZ2: WEETANGERA / BELCONNEN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
24	12/01/2022	16/05/2025	YES	NO	NO	CF: PHILLIP / WODEN VALLY	YES Development application lodged or made before 2	2	UNITS	500mj/hr - 5kpa
25	3/05/2024	26/09/2024	YES	NO	NO	CZ1: CITY / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	6	Commercial	830mj/hr - 5kpa
26	16/07/2024	24/07/2024	YES	NO	NO	CZ3: BELCONNEN / BELCONNEN	YES Building approval issued before 2 March 2024	6	Commercial	470mj/hr - 5kpa
27	17/10/2024	22/10/2024	YES	NO	NO	CZ1: CITY / CANBERRA CENTRAL	YES Development application lodged or made before 2	6	Commercial	310mj/hr -2.75kpa
28	11/12/2024	17/12/2024	YES	NO	NO	CZ2: PHILLIP / WODEN VALLEY	YES Development application lodged or made before 2	6	Commercial	209mj/hr - 2.75kpa
29	29/11/2024	23/01/2025	YES	NO	NO	CZ2: PHILLIP / WODEN VALLEY	YES Development application lodged or made before 2	6	Commercial	900 Mj/hr - 5kpa
30	1/09/2025	23/01/2025	YES	NO	NO	CZ2: PHILLIP / WODEN VALLEY	YES Development application lodged or made before 2	6	Commercial	240mj/hr - 5kpa
31	14/05/2025	23/05/2025	YES	NO	NO	CZ1: CITY / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	6	Commercial	682mj/hr - 5kpa
32	4/06/2022	20/01/2025	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
33	22/11/2022	9/04/2024	YES	NO	NO	RZ1: FORREST / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
34	1/05/2023	7/08/2024	YES	NO	NO	RZ1: KALEEN / BELCONNEN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
35	31/03/2023	10/02/2024	YES	NO	NO	RZ1: MONCRIEFF / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
36	21/04/2023	31/07/2024	YES	NO	NO	RZ1: GRIFFITH / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
37	21/04/2023	24/07/2024	YES	NO	NO	RZ1: AINSLIE / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
38	5/03/2023	22/08/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
39	5/08/2023	22/07/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
40	5/09/2023	27/09/2024	YES	NO	NO	RZ1: WANNIASSA / TUGGERANONG	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
41	15/05/2023	8/07/2024	YES	NO	NO	RZ1: MCKELLAR / BELCONNEN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
42	23/05/2023	18/07/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
43	31/05/2023	8/07/2024	YES	NO	NO	RZ2: LYONS / WODEN VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
44	6/02/2023	9/09/2024	YES	NO	NO	RZ1: RIVETT / WESTON CREEK	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
45	6/08/2023	21/08/2024	YES	NO	NO	RZ1: GRIFFITH / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
46	6/09/2023	13/08/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
47	19/06/2023	23/08/2024	YES	NO	NO	RZ3: THROSBY / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
48	19/06/2023	8/12/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
49	23/06/2023	12/11/2024	YES	NO	NO	RZ1: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
50	26/06/2023	15/07/2024	YES	NO	NO	RZ1: REID / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
51	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
52	7/07/2023	11/07/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
53	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
54	7/07/2023	11/07/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
55	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
56	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
57	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
58	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
59	7/07/2023	15/11/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
60	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
61	7/07/2023	11/07/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
62	7/07/2023	11/07/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
63	7/07/2023	11/07/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
64	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
65	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa

66	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
67	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
68	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
69	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
70	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
71	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
72	7/07/2023	11/08/2024	YES	NO	NO	RZ5: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
73	19/07/2023	31/07/2024	YES	NO	NO	RZ1: CURTIN / WODEN VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
74	19/07/2023	9/03/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
75	20/07/2023	13/11/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
76	27/07/2023	7/05/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
77	14/08/2023	13/11/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
78	24/08/2023	7/03/2024	YES	NO	NO	RZ1: MONCRIEFF / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
79	9/07/2023	29/07/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
80	9/12/2023	7/02/2024	YES	NO	NO	RZ1: FARRER / WODEN VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
81	15/09/2023	12/05/2024	YES	NO	NO	RZ1: DOWNER / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
82	21/09/2023	8/06/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
83	22/09/2023	8/01/2024	YES	NO	NO	RZ1: DEAKIN / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
84	10/03/2023	18/09/2024	YES	NO	NO	RZ2: EVATT / BELCONNEN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
85	10/03/2023	9/04/2024	YES	NO	NO	RZ2: EVATT / BELCONNEN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
86	10/06/2023	23/08/2024	YES	NO	NO	RZ1: THROSBY / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
87	16/10/2023	19/11/2024	YES	NO	NO	RZ1: HACKETT / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
88	16/10/2023	10/10/2024	YES	NO	NO	RZ1: FORDE / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
89	25/10/2023	7/12/2024	YES	NO	NO	RZ1: BONNER / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
90	27/10/2023	18/07/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
91	11/01/2023	27/06/2024	YES	NO	NO	RZ2: WANNIASSA / TUGGERANONG	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
92	11/06/2023	11/12/2024	YES	NO	NO	RZ1: DEAKIN / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
93	17/11/2023	27/09/2024	YES	NO	NO	RZ1: RICHARDSON / TUGGERANONG	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
94	30/11/2023	13/08/2024	YES	NO	NO	RZ1: DOWNER / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
95	1/05/2024	7/03/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
96	1/08/2024	21/10/2024	YES	NO	NO	RZ1: DOWNER / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
97	1/08/2024	24/09/2024	YES	NO	NO	RZ1: REID / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
98	16/01/2024	12/02/2024	YES	NO	NO	RZ1: GARRAN / WODEN VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
99	16/01/2024	28/08/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
100	16/01/2024	28/06/2024	YES	NO	NO	RZ1: GARRAN / WODEN VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	620Mj/hr -2.75kpa
101	23/01/2024	9/11/2024	YES	NO	NO	RZ1: KALEEN / BELCONNEN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
102	24/01/2024	8/12/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
103	24/01/2024	23/08/2024	YES	NO	NO	RZ3: THROSBY / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
104	24/01/2024	16/07/2024	YES	NO	NO	DES: FORREST / CANBERRA CENTRAL	YES - NCA Land	1	NEW HOMES	520Mj/hr -2.75kpa
105	2/07/2024	7/03/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
106	21/02/2024	13/08/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
107	22/02/2024	25/11/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
108	23/02/2024	15/11/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa

109	23/02/2024	11/05/2024	YES	NO	NO	RZ1: FORREST / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
110	27/02/2024	16/09/2024	YES	NO	NO	RZ1: YARRALUMLA / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
111	28/02/2024	9/05/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
112	3/06/2024	12/12/2024	YES	NO	NO	RZ1: NARRABUNDA / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
113	3/06/2024	28/11/2024	YES	NO	NO	RZ2: GRIFFITH / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
114	3/06/2024	28/11/2024	YES	NO	NO	RZ2: GRIFFITH / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
115	13/03/2024	13/03/2025	YES	NO	NO	RZ4: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
116	13/03/2024	3/12/2025	YES	NO	NO	RZ4: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
117	13/03/2024	3/12/2025	YES	NO	NO	RZ4: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
118	13/03/2024	13/03/2025	YES	NO	NO	RZ4: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
119	13/03/2024	3/12/2025	YES	NO	NO	RZ4: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
120	13/03/2024	3/12/2025	YES	NO	NO	RZ4: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
121	13/03/2024	3/12/2025	YES	NO	NO	RZ4: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
122	13/03/2024	3/12/2025	YES	NO	NO	RZ4: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
123	15/03/2024	14/03/2025	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
124	20/03/2024	26/11/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
125	4/08/2024	1/10/2025	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
126	4/10/2024	31/10/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
127	15/04/2024	26/11/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
128	16/04/2024	18/07/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
129	24/04/2024	28/01/2025	YES	NO	NO	RZ1: O'CONNOR / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
130	24/04/2024	17/07/2024	YES	NO	NO	RZ1: THEODORE / TUGGERANONG	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
131	5/01/2024	1/08/2025	YES	NO	NO	RZ1: DEAKIN / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
132	13/05/2024	7/10/2024	YES	NO	NO	RZ1: DEAKIN / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	605Mj/hr -2.75kpa
133	14/05/2024	28/06/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
134	22/05/2024	12/04/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
135	27/05/2024	7/04/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
136	29/05/2024	23/07/2024	YES	NO	NO	RZ1: ARANDA / BELCONNEN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
137	31/05/2024	15/08/2024	YES	NO	NO	RZ1: CAMPBELL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
138	6/04/2024	7/04/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
139	6/04/2024	7/05/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
140	6/06/2024	7/05/2024	YES	NO	NO	RZ1: COOMBS / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
141	6/06/2024	7/01/2024	YES	NO	NO	RZ2: WEETANGERA / BELCONNEN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
142	6/07/2024	7/01/2024	YES	NO	NO	RZ2: PAGE / BELCONNEN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
143	13/06/2024	7/04/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
144	18/06/2024	7/10/2024	YES	NO	NO	RZ2: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
145	19/06/2024	27/09/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
146	20/06/2024	7/03/2024	YES	NO	NO	RZ1: MONCRIEFF / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
147	20/06/2024	7/03/2024	YES	NO	NO	RZ4: DENMAN PROSPECT / MOLONGLO VALLY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
148	24/06/2024	17/07/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
149	24/06/2024	25/10/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
150	25/06/2024	8/12/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
151	27/06/2024	24/07/2024	YES	NO	NO	RZ1: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa

152	28/06/2024	11/05/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
153	28/06/2024	17/07/2024	YES	NO	NO	RZ1: WANNIASSA / TUGGERANONG	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
154	7/03/2024	8/02/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
155	7/03/2024	8/02/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
156	7/05/2024	8/02/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
157	7/05/2024	29/07/2024	YES	NO	NO	RZ1: BONNER / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
158	7/09/2024	8/06/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
159	7/11/2024	29/10/2024	YES	NO	NO	RZ1: O'CONNER / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
160	7/12/2024	25/07/2024	YES	NO	NO	RZ1: KALEEN / BELCONNEN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
161	17/07/2024	22/08/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
162	17/07/2024	28/10/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
163	23/07/2024	9/03/2024	YES	NO	NO	RZ1: PEARCE / WODEN VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	1260Mj/hr -2.75kpa
164	24/07/2024	8/06/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
165	25/07/2024	9/05/2024	YES	NO	NO	RZ2: TORRENS / WODEN VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
166	25/07/2024	9/05/2024	YES	NO	NO	RZ2: MAWSON / WODEN VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
167	25/07/2024	31/10/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
168	26/07/2024	26/08/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
169	26/07/2024	21/08/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
170	26/07/2024	20/08/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
171	26/07/2024	20/08/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
172	26/07/2024	29/08/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
173	26/07/2024	26/08/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
174	26/07/2024	9/03/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
175	8/01/2024	22/08/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
176	8/02/2024	13/08/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
177	8/06/2024	29/08/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
178	8/06/2024	20/08/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
179	8/06/2024	20/08/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
180	8/06/2024	26/08/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
181	8/06/2024	21/08/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
182	8/12/2024	15/01/2025	YES	NO	NO	RZ3: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
183	8/12/2024	2/05/2025	YES	NO	NO	RZ3: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
184	13/08/2024	20/09/2024	YES	NO	NO	RZ3: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
185	13/08/2024	20/09/2024	YES	NO	NO	RZ3: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
186	15/08/2024	9/03/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
187	16/08/2024	12/03/2024	YES	NO	NO	RZ2: GARRAN / WODEN VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	3202Mj/hr -100kpa
188	19/08/2024	19/09/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
189	19/08/2024	20/09/2024	YES	NO	NO	RZ1: AINSLIE / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
190	27/08/2024	10/03/2024	YES	NO	NO	RZ1: LYNEHAM / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
191	28/08/2024	12/04/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
192	30/08/2024	30/09/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
193	30/08/2024	20/09/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
194	9/03/2024	10/01/2024	YES	NO	NO	RZ2: MCKELLAR / BELCONNEN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa

195	9/03/2024	18/11/2024	YES	NO	NO	RZ1: DEAKIN / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
196	9/04/2024	19/09/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
197	9/04/2024	19/09/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
198	9/06/2024	29/10/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
199	9/06/2024	29/10/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
200	9/06/2024	30/10/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
201	9/09/2024	12/05/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
202	9/09/2024	25/09/2024	YES	NO	NO	RZ1: YARRALUMLA / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	560Mj/hr -2.75kpa
203	9/11/2024	31/10/2024	YES	NO	NO	RZ1: MONCRIEFF / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
204	9/11/2024	30/04/2025	YES	NO	NO	RZ1: YARRALUMLA / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	460Mj/hr -2.75kpa
205	9/11/2024	27/09/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
206	16/09/2024	10/04/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
207	16/09/2024	30/09/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
208	16/09/2024	27/09/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
209	19/09/2024	10/02/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
210	24/09/2024	10/02/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
211	25/09/2024	16/10/2024	YES	NO	NO	RZ1: O'CONNER / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
212	26/09/2024	28/10/2024	YES	NO	NO	RZ1: WRIGHT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
213	26/09/2024	10/03/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
214	10/02/2024	14/01/2025	YES	NO	NO	CZ6: WATSON / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
215	10/02/2024	28/10/2024	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
216	10/02/2024	31/10/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
217	10/03/2024	11/11/2024	YES	NO	NO	RZ1: YARRALUMLA / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
218	10/03/2024	17/10/2024	YES	NO	NO	RZ1: ARANDA / BELCONNEN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
219	10/04/2024	28/11/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
220	10/04/2024	10/10/2024	YES	NO	NO	RZ1: O'CONNER / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
221	10/04/2024	25/10/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
222	10/08/2024	31/10/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
223	10/09/2024	14/01/2025	YES	NO	NO	RZ2: FADDEN / TUGGERANONG	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
224	15/10/2024	26/02/2025	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
225	16/10/2024	25/11/2024	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
226	17/10/2024	13/11/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
227	22/10/2024	22/11/2024	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
228	24/10/2024	22/11/2024	YES	NO	NO	RZ1: CASEY / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
229	24/10/2024	13/11/2024	YES	NO	NO	RZ1: LYNEHAM / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
230	25/10/2024	28/10/2024	YES	NO	NO	RZ1: YARRALUMLA / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
231	29/10/2024	15/05/2025	YES	NO	NO	RZ1: TURNER / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
232	30/10/2024	26/11/2024	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
233	31/10/2024	13/11/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
234	31/10/2024	13/11/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
235	31/10/2024	13/11/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
236	31/10/2024	13/11/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
237	11/05/2024	29/11/2024	YES	NO	NO	RZ1: YARRALUMLA / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa

238	11/06/2024	1/07/2025	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
239	14/11/2024	5/06/2025	YES	NO	NO	RZ1: KALEEN / BELCONNEN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
240	25/11/2024	29/11/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
241	25/11/2024	29/11/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
242	25/11/2024	28/11/2024	YES	NO	NO	RZ5: RED HILL / CANBERRA CENTRAL	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
243	27/11/2024	12/04/2024	YES	NO	NO	RZ1: WRIGHT / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
244	27/11/2024	15/01/2025	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
245	12/05/2024	17/03/2025	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
246	12/11/2024	15/01/2025	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
247	12/11/2024	1/10/2025	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
248	20/12/2024	15/01/2025	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
249	20/12/2024	17/03/2025	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
250	1/10/2025	20/01/2025	YES	NO	NO	RZ3: DOWNER / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
251	16/01/2025	2/05/2025	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
252	17/01/2025	2/05/2025	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
253	21/01/2025	20/02/2025	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
254	21/01/2025	19/02/2025	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
255	21/01/2025	19/02/2025	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
256	21/01/2025	18/02/2025	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
257	23/01/2025	19/02/2025	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
258	23/01/2025	18/02/2025	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
259	31/01/2025	17/02/2025	YES	NO	NO	RZ1: RED HILL / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
260	2/05/2025	19/02/2025	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
261	2/11/2025	25/02/2025	YES	NO	NO	RZ1: WRIGHT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
262	2/11/2025	18/02/2025	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
263	20/02/2025	25/02/2025	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Development application lodged or made before 2	1	NEW HOMES	320Mj/hr -2.75kpa
264	28/02/2025	4/02/2025	YES	NO	NO	RZ1: O'CONNER / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
265	3/03/2025	14/03/2025	YES	NO	NO	RZ3: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
266	3/04/2025	21/03/2025	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
267	3/11/2025	18/03/2025	YES	NO	NO	RZ1: O'CONNER / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
268	3/11/2025	21/03/2025	YES	NO	NO	RZ1: DENMAN PROSPECT / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
269	14/03/2025	23/04/2025	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
270	17/03/2025	15/04/2025	YES	NO	NO	RZ3: THROSBY / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
271	24/03/2025	23/04/2025	YES	NO	NO	RZ1: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
272	25/03/2025	29/04/2025	YES	NO	NO	RZ1: WHITLAM / MOLONGLO VALLEY	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
273	4/02/2025	19/05/2025	YES	NO	NO	RZ1: THROSBY / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
274	17/04/2025	19/05/2025	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
275	13/05/2025	6/12/2025	YES	NO	NO	RZ3: TAYLOR / GUNGAHLIN	YES Building approval issued before 2 March 2024	1	NEW HOMES	320Mj/hr -2.75kpa
276	7/07/2023	2/11/2025	YES	NO	NO	CF: PHILLIP / WODEN VALLY	YES Building approval issued before 2 March 2024	2	UNITS	3575Mj/hr -5kpa
277	28/02/2024	29/05/2025	YES	NO	NO	CZ5: LYNEHAM / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	2	UNITS	3829Mj/hr -5kpa
278	28/02/2024	29/05/2025	YES	NO	NO	CZ5: LYNEHAM / CANBERRA CENTRAL	YES Building approval issued before 2 March 2024	2	UNITS	3829Mj/hr -5kpa
279	5/09/2024	2/11/2025	YES	NO	NO	CF: PHILLIP / WODEN VALLY	YES Building approval issued before 2 March 2024	2	UNITS	7150Mj/hr -5kpa
280	16/07/2024	16/07/2024	YES	NO	NO	DES: CAMPBELL / CANBERRA CENTRAL	YES - NCA Land	2	UNITS	320Mj/hr -2.75kpa

[illegible]

[illegible]

367	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
368	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
369	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
370	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
371	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
372	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
373	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
374	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
375	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
376	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
377	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
378	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
379	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
380	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
381	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
382	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
383	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
384	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
385	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
386	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
387	12/07/2023	19/12/2024	YES	NO	NO	RZ5: COOMBS / MOLONGLO VALLEY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
388	13/05/2024	20/01/2025	YES	NO	NO	RZ4: DENMAN PROSPECT / MOLONGLO VALLY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
389	13/05/2024	20/01/2025	YES	NO	NO	RZ4: DENMAN PROSPECT / MOLONGLO VALLY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
390	13/05/2024	21/01/2025	YES	NO	NO	RZ4: DENMAN PROSPECT / MOLONGLO VALLY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
391	13/05/2024	20/01/2025	YES	NO	NO	RZ4: DENMAN PROSPECT / MOLONGLO VALLY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
392	13/05/2024	21/01/2025	YES	NO	NO	RZ4: DENMAN PROSPECT / MOLONGLO VALLY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
393	13/05/2024	21/01/2025	YES	NO	NO	RZ4: DENMAN PROSPECT / MOLONGLO VALLY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
394	1/09/2025	21/01/2025	YES	NO	NO	RZ4: DENMAN PROSPECT / MOLONGLO VALLY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa
395	1/09/2025	21/01/2025	YES	NO	NO	RZ4: DENMAN PROSPECT / MOLONGLO VALLY	YES Development application lodged or made before 2	2	UNITS	320 MJ/hr , 2.75 kpa

E102	Does the licensee provide customers with the required information set out in the Climate Change and Greenhouse Gas Reduction (Information gas distributor must give customers) Direction 2023 ?	Yes
E102(a)	In relation to E102, please provide a link to the relevant information or reasons for non-compliance.	Natural gas connection

END OF E1

Authorising and contact officers

Authorising officer

The licensee's officer authorising the release of this information is

Name	Sam Sachse
Title/position in organisation	General Manager- Evonergy
Postal address	GPO Box 366, Canberra ACT 2601
Telephone	02 62935850
Email	sam.sachse@evoenergy.com.au

Contact officer

The licensee's contact officer for regulatory and compliance matters is

Name	Jane Godkin
Title/position in organisation	Regulatory Technical Compliance Manager - Strategy and Operations
Postal address	GPO Box 366, Canberra ACT 2601
Telephone	02 6248 3453
Email	jane.godkin@evoenergy.com.au