

## Evoenergy substations identified for community batteries

Evoenergy has been approached by local industry about community batteries in the ACT. We have identified distribution substations where battery projects may address potential constraints. More information is on our website [here](#).

| Substation identifier | Spare circuit size (A) | Capacity (VA) | Type     |
|-----------------------|------------------------|---------------|----------|
| MONCRIEFF B1 S81      | 630                    | 315000        | Padmount |
| GUNGAHLIN B1 S78      | at least 315A          | 315000        | Padmount |
| AMAROO B11 S88        | at least 315A          | 250000        | Padmount |
| AMAROO B22 S30        | at least 315A          | 250000        | Padmount |
| HARRISON B14 S152     | 630                    | 315000        | Padmount |
| LAWSON B4 S13         | 630 A                  | 315000        | Padmount |
| DUNLOP B3 S194        | at least 315A          | 315000        | Padmount |
| THROSBY B1 S29        | 630                    | 315000        | Padmount |
| AINSLIE B25 S24       | 630                    | 250000        | Padmount |
| FORDE B1 S88          | at least 315A          | 315000        | Padmount |
| FRANKLIN B40 S62      | at least 315A          | 315000        | Padmount |
| MACQUARIE B1 S4       | 600                    | 250000        | Padmount |
| HARRISON B3 S130      | at least 315A          | 315000        | Padmount |
| KINGSTON B1 S24       | 630                    | 250000        | Padmount |
| FADDEN B4 S400        | at least 315A          | 250000        | Padmount |
| FRANKLIN B1 S30       | at least 315A          | 315000        | Padmount |
| BONNER B3 S26         | at least 315A          | 315000        | Padmount |
| DUNLOP B1 S149        | at least 315A          | 315000        | Padmount |
| MACQUARIE S16         | 400                    | 250000        | Padmount |
| CONDER B25 S119       | at least 315A          | 250000        | Padmount |
| AINSLIE B1 S3         | at least 315A          | 250000        | Padmount |
| GORDON B1 S563        | 630                    | 315000        | Padmount |
| BONNER B2 S132        | 630                    | 315000        | Padmount |
| NICHOLLS B11 S116     | at least 315A          | 250000        | Padmount |

|                                 |               |        |          |
|---------------------------------|---------------|--------|----------|
| HARRISON B18 S15                | at least 315A | 315000 | Padmount |
| CURTIN B25 S16                  | at least 315A | 250000 | Padmount |
| TURNER B37 S28                  | 315           | 250000 | Padmount |
| BONNER B1 S141                  | at least 315A | 315000 | Padmount |
| CONDER B1 S304                  | at least 315A | 250000 | Padmount |
| DUNLOP B1 S159                  | at least 315A | 315000 | Padmount |
| HIGGINS B16 S45                 | 315           | 250000 | Padmount |
| BANKS B11 S96                   | at least 315A | 315000 | Padmount |
| FORREST B7 S38                  | 630           | 250000 | Padmount |
| COOMBS B1 S34                   | at least 315A | 315000 | Padmount |
| MELBA S26 B7                    | 400           | 250000 | Padmount |
| COREE B213                      | 630           | 315000 | Padmount |
| FLOREY B26 S144                 | at least 315A | 315000 | Padmount |
| THROSBY B1 S8                   | 630           | 500000 | Padmount |
| THROSBY B1 S41                  | at least 315A | 500000 | Padmount |
| ARANDA B1 S30                   | 400 A         | 250000 | Padmount |
| COOMBS B10 S26                  | at least 315A | 315000 | Padmount |
| COOMBS B16 S52 (Near to B2 S16) | at least 315A | 500000 | Padmount |
| NICHOLLS B1 S137                | at least 315A | 250000 | Padmount |
| GRIFFITH B76 S90                | 400           | 250000 | Padmount |
| YARRALUMLA S77                  | 400*2         | 250000 | Padmount |