



- NOTES:
1. ALL TRENCHES TO HAVE A 1:60 MIN FALL TOWARDS SUMP.
 2. ALL STEEL TO BE HOT DIP GALVANISED AFTER FABRICATION.
 3. ALUMINIUM CHECKER PLATE COVERS SHALL BE STRAIGHT & FLAT AND SHALL HAVE A MAXIMUM AREA OF 1m².
 4. ALUMINIUM CHECKER PLATE COVERS TO BE PROVIDED WITH 2 OF 10mm X 30mm OVAL SHAPED LIFTING SLOTS AND TWO LIFTING KEYS.
 5. TRENCH DEPTH SHALL NOT EXCEED 1200mm WITHOUT APPROVAL FROM EVOENERGY.
 6. FOR X & Y, REFER PROJECT SPECIFIC DRAWING. REFER RELEVANT INDOOR SUBSTATION TYPICAL LAYOUT FOR GUIDANCE.

NOT TO SCALE

C	COPIED TO NEW FRAME, LOGO UPDATED	26/03/2008	AC	GA	The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy. 2018.
D	LOGO AND REFERENCES UPDATED	18/03/2018	B. Suthar	W. Ibrahim	
E	FRAME, TRENCH AND NOTATION UPDATED	12/09/2023	K. Vedanti	N. Azizi	
No	Revision	Date	Checked	Approved	ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2018.

 STANDARD SUBSTATION "T" AND "L" TRENCH DETAILS		Drawn:	S.Read	Date:	15/11/1995	
		Designed:	E. Amaratunga			
		Checked:	M. Charlton			
		Approved:				
Project No:	Status: Current	A4	4931-01	REV	E	
Work Pack No:	File:					