



NOTES:

1. EYE CAST IN CONCRETE SLAB MUST TAKE LOADS OF 2000kg IN ANY DIRECTION.
2. HAULAGE EYE STEEL PLATE SHALL COMPLY WITH AS3678 GRADE 250, THE STEEL BAR SHALL COMPLY WITH AS3679.1 GRADE 250 AND WELDING TO AS1554.
3. EYE SHALL BE HOT DIP GALVANISED AFTER FABRICATION TO AS4680.
4. HAULAGE EYES REQUIRED IN CABLE TRENCHES SHALL BE LOCATED IN TRENCH WALL 200mm ABOVE FLOOR UNLESS OTHERWISE INDICATED.
5. ALL DIMENSIONS IN MILLIMETRES.
6. DO NOT SCALE FROM DRAWING.

F	LOGO AND REFERENCES UPDATED	18/03/2018	B. Suthar	W. Ibrahim	The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy, 2018.
E	UPDATED AS PART OF CHAMBER SUBSTATION STANDARDS REVIEW	29/11/2017	C. Desai	W. Ibrahim	
D	LOGO UPDATED, NOTES 5 & 6 ADDED	31/03/2008	AC	GA	
No	Revision	Date	Checked	Approved	ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2018.

 STANDARD SUBSTATION HAULAGE & LIFTING EYE		Drawn:	Date:	
		Designed:	A-NNR	
		Checked:		
		Approved:	FRASER	
Project No:	Status: Current	A4	4951-09	REV
Work Pack No:	File:			F