


RISER DOOR (SINGLE) IN FIRE WALLS

USED ONLY WHERE THE SUBSTATION IS LOCATED ON FLOORS ABOVE GROUND LEVEL AND WHERE ACCESS IS REQUIRED



FIRE DOOR & FIXED PANEL:—
ALL ELEMENTS MUST BE IDENTICAL TO ITEMS APPROVED ON FIRE TESTED DOORS. WATERPROOF FACES FOR EXTERNAL DOORS.

DOOR CLOSER:—
SURFACE MOUNTED PARALLEL ARM

HINGES:—
STEEL, GALV STEEL OR STAINLESS STEEL. NUMBER VARIES WITH DOOR SIZE

KEY CYLINDER:—(WHERE REQUIRED)
EVOENERGY EXCLUSIVE PROFILE

DOOR LOCK & FURNITURE
MORTISE NIGHT LATCH WITH AUTO-DEADLOCK FUNCTION. KEY CYLINDER OUTSIDE, TURN INSIDE BETWEEN 900 & 1200 ABOVE FFL.

DOOR OPERATION:—
THE DOOR MUST CLOSE AND LATCH INTO THE STRIKE AND LOCK WITH EACH DOOR OPERATION. TURN SNIB INSIDE FOR ESCAPE AT ALL TIMES.

THRESHOLD & BUND:—
INCOMBUSTABLE THRESHOLD OR SILL WITH 100 x 100 min. MASONRY BUND

EXTERNAL ELEVATION

DOOR SIZES VARY WITH SPECIFIC PROJECT CONDITIONS

BCA REQUIREMENTS

FIRE DOOR FRL	(2hr) TO COMPLY WITH AS1905.1	C2.13(a)
FIRE DOOR SIGNS	"FIRE SAFETY DOOR DO NOT OBSTRUCT DO NOT KEEP OPEN"	D2.23(b)
ESCAPE HARDWARE	LEVER HANDLE BETWEEN 900 & 1200 ABOVE FFL	D2.22
DOOR HEIGHT	MINIMUM CLEAR UNOBSTRUCTED HEIGHT 1980mm.	D1.6(a)
DOOR WIDTH	MINIMUM CLEAR UNOBSTRUCTED WIDTH 750mm.	D1.6(f)

AUSTRALIAN STANDARDS

SAFETY SIGNS	"DANGER HIGH-VOLTAGE-KEEP OUT" 350W X 175H	AS1319
FIRE DOOR	TESTED LATCHING HARDWARE ONLY. NO HOLD OPEN BOLTS.	AS1905.1

EVOENERGY REQUIREMENTS

DIRECTION OF SWING	TO SWING IN THE DIRECTION OF ESCAPE (PUSH OUTWARDS)
ELECTRIC DOOR RELEASE	NOT PERMITTED
BUND	100 x 100mm MINIMUM 1200mm MAXIMUM LENGTH MASONRY BUND SILICON SEAL TO SILL & WALL

FRL = FIRE RESISTANCE LEVEL

No	Revision	Date	Checked	Approved
D	LOGO AND REFERENCES UPDATED	18/03/2018	B. Suthar	W. Ibrahim
C	UPDATED AS PART OF CHAMBER SUBSTATION STANDARDS REVIEW	29/11/2017	C. Desai	W. Ibrahim
B	LOGO UPDATED		AC	GA

The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy. 2018.

ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2018.



**HIGH VOLTAGE RISER DOOR (SINGLE)
IN FIRE RATED WALLS FOR
INDOOR CHAMBER SUBSTATION**

Drawn:	R. Cross	Date:	1/07/1997
Designed:	E. Amaratunga		
Checked:	M. Charlton		
Approved:			

Project No:	Status: Current
Work Pack No:	File:

A4	4951-26	D
----	---------	---