



LEGEND

- ① (a) SERVICE PROTECTION DEVICE - UNDERGROUND SUPPLY
OR
(b) SEALABLE ACTIVE LINK(s) - OVERHEAD SUPPLY (IF REQUIRED)
- ② SEALABLE NEUTRAL LINK
- NETWORK AREA
- CUSTOMER AREA
(METERING EQUIPMENT AND DISTRIBUTION BOARD)

NOTES

1. ITEM ② IS TO BE PROVIDED BY THE CONTRACTOR.
2. IT IS ESSENTIAL THAT THE OPENING AND CLOSING OF THE METER PANEL DOES NOT TRANSFER ANY MECHANICAL STRESS OR MOVEMENT TO THE TERMINATION OF THE SERVICE CABLE OR CONSUMER MAINS (PARTICULARLY THE NEUTRAL) THEREFORE; ALL SERVICE CABLES AND CONSUMER MAINS MUST BE SECURED TO THE METER PANEL. INSULATED CLAMPS, CLIPS OR CABLE TIES AND CABLE TIE MOUNTS CAN BE USED TO SECURE THE CABLES. PLEASE NOTE THAT CLAMPS, CLIPS AND CABLE TIE MOUNTS MUST BE ATTACHED TO THE PANEL WITH FASTENERS, SELF-ADHESIVE PRODUCTS ARE NOT ACCEPTABLE.
3. TERMINAL SCREWS OF THE NEUTRAL LINK SHALL BE ACCESSIBLE WITHOUT REMOVAL OF OTHER ASSETS.
i.e. SERVICE FUSES, METER.
4. ALL DIMENSIONS ARE IN MILLIMETRES

SWITCHBOARD LAYOUT
DOMESTIC
FRONT VIEW

G	NOTE 2 ADDED	18/07/2016	C. Desai	W. Ibrahim	Drawn:	Designed:	evoenergy STANDARD SWITCHBOARD ARRANGEMENT DOMESTIC	Scale: 1:4	Date:	Sheet No:
H	UPDATED FOR POWER OF CHOICE REFORMS	2/11/2017	C. Desai	W. Ibrahim	Checked:			Work Pack No:	File:	
I	LOGO AND REFERENCES UPDATED TO EVOENERGY	8/01/2018	C. Desai	W. Ibrahim	Approved: R. McMurray	28/02/2014		Status:	Current	
F	SEALABLE NEUTRAL LINK RE-POSITIONED	24/01/2014	P.S.	R.M.	Project No:			A3	8911-2211-101	Rev 1
No	Revision	Date	Checked	Approved						
The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy. 2017.					ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2017.					