



NOTES:

1. THIS SKETCH ILLUSTRATES REQUIREMENTS SET OUT IN DETAIL AND SHOULD BE READ IN CONJUNCTION WITH EVOENERGY SERVICE AND INSTALLATION RULES.
2. ALL DIMENSIONS ARE IN MILLIMETRES.
3. CONDUIT TO CONNECT TO EXISTING EVOENERGY CONDUIT, OTHERWISE 850mm MIN - 1000mm MAX COVER.
4. IF CONDUIT IS LOWER THAN STREET LEVEL INSTALL DRAINAGE HOLE AS DETAILED IN EVOENERGY SERVICE AND INSTALLATION RULES.

				Drawn:	Designed: A-NNR	<p>TYPICAL UNDERGROUND SERVICE CABLE CONDUIT REQUIREMENTS FOR INSTALLATIONS EXCEEDING 100AMPS PER PHASE</p>	Scale:	Date: 16/03/1999	Sheet No:	
				Checked:			Work Pack No:	File:		
				Approved: A-NNR			Status: Current			
				Project No:			A3	8912-04	Rev G	
<small>The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy. 2017.</small>				<small>ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2017.</small>						