


**NOTES:**

1. SIDEWALK STAYS ARE EXTERMEY LIMITED IN THEIR HOLDING CAPACITY (THE SHORTER THE STRUT THE LESS LOAD THEY CAN HOLD) AND SHOULD NOT BE USED TO REPLACE A STANDARD STAY. (THE HOLDING CAPACITY OF A STANDARD STAY IS APPROXIMATELY FOUR TIMES GREATER THAN A SIDEWALK STAY WITH A LONG STRUT AND APPROXIMATELY EIGHT TIMES GREATER THAN A SIDEWALK STAY WITH A SHORT STRUT.)
2. STAY STRUTS OF TWO LENGTHS ARE AVAILABLE - 1200mm (D108-0015, 1174965) AND 2400mm (D108-0005, 1174976).
3. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN.

ITEM	UA TYPE	DESCRIPTION	STOCK CODE	QTY	DRAWING NO
1	P	STAY WIRE GUARD, WHITE, PVC, NON SLIT, 2m LENGTH	1065737	1	D104-0042
2	P	WASHER, SPRING, M20, GALV	1194376	4	D111-0007
3	P	BOLT, M16 x 200mm, GALV, GR 4.6, WITH NUT	1059117	4	D111-0042
4	P	CONDUCTOR, AERIAL, 19/2.75, 19/4 STEEL, SC/GZ, 113mm <sup>2</sup>	1192933	20m	D102-0031
5	P	GUY LOK, 19/2.75, SC/GZ, STEEL, CONDUCTOR	1192922	1	D103-0245
6	P	WASHER, SQUARE, STAY, M20, 250 x 250 x 6mm, GALV	1065713	1	D111-0013
7	P	STAY ROD, M20 x 2500mm LG, GALV, C/W HEX NUT & THIMBLE	1065725	1	D104-0043
8	P	INSULATOR, GUY, 222kN, 115 x 216mm LG	1164302	1	D104-0041
9	P	GRIP, FOR dia 16mm WIRE ROPE, HEAVY DUTY, GALV	1066262	4	D104-0048
10	P	GRIP, DEADEND (19/2.75) SC/GZ, CONDUCTOR 9.75mm O.D. (ORANGE)	1192911	3	D103-0074
11	P	STRUT, SIDEWALK STAY, 2400mm LONG	1174976	1	D108-0005
12	P	WASHER, FLAT M16, GALV	1060296	8	D111-0016
13	I	INTERFACE, POLE BAND TO SUIT	SELECT	4	D204-0018
14	I	INTERFACE, BRACKET, STAY C/W THIMBLE TO SUIT	SELECT	1	D204-0018

No.	DESCRIPTION	CHKD	AUTH	DATE
A	PRELIMINARY		MJB WJC	30/09/2014
B	UPDATED AS PER UOM PROJECT		JJP WNI	19/02/2016
C	EVOENERGY BRANDING		NAA WJC	27/01/2021



Drawn:	WASMER
Designed:	
Checked:	M. Butson 25/06/2014
Branch Engineer:	W. Cleland 25/06/2014
Branch Manager:	
Old Drawing No. and Revisions:	

STANDARD CONSTRUCTION, DISTRIBUTION  
OVERHEAD, CONDUCTORS AND ACCESSORIES,  
SA, STAYS,  
SIDEWALK STAY ON A CONCRETE OR COMPOSITE POLE  
(19/2.75 SC)

Scale:	N.T.S.	Date:		Sheet No.:	
Project No.:		Stock Code:			
Status:	Current				
A1	D204-0013				Rev C