



TABLE : VEGETATION CLEARANCE REFERENCE TABLE ("C")

| AREA | INFRASTRUCTURE TYPE | SPAN LENGTH | MINIMUM CLEARANCE FROM AERIAL LINES | SPECIAL REQUIREMENTS | VEGETATION PERMITTED TO OVERHANG AERIAL LINES |
|----------------|--|-------------|-------------------------------------|---|---|
| URBAN OR RURAL | BARE/INSULATED LV DISTRIBUTION NETWORK | <100m | 2.5 m* | THE MINIMUM DISTANCE FROM ANY PART OF AN AERIAL LINE IS TO BE MEASURED FROM THE NEAREST POINT TO WHICH THE LINE SAGS OR SWINGS. * ADDITIONAL 0.5m CLEARANCE TO BE ADDED TO ALL BARE CONDUCTOR CLEARANCES FOR BUSH FIRE PRONE AREAS. | 'YES' FOR URBAN & 'NO' FOR RURAL |
| URBAN OR RURAL | BARE/INSULATED LV DISTRIBUTION NETWORK | >100m | 3.5m* | THE MINIMUM DISTANCE FROM ANY PART OF AN AERIAL LINE IS TO BE MEASURED FROM THE NEAREST POINT TO WHICH THE LINE SAGS OR SWINGS. * ADDITIONAL 0.5m CLEARANCE TO BE ADDED TO ALL BARE CONDUCTOR CLEARANCES FOR BUSH FIRE PRONE AREAS. | 'YES' FOR URBAN & 'NO' FOR RURAL |

NOTES:

- TREES MUST BE PRUNED TO MAINTAIN THE MINIMUM CLEARANCE; FOR TREES > 3m: TREE HEIGHT AND BRANCHES MUST BE PRUNED TO A HEIGHT EQUAL TO THE CLEARANCE FROM THE POLE.
- SAG MUST BE CHECKED WHEN LINE IS OPERATING AT IT'S DESIGN TEMPERATURE RATING.
- OVERHEAD LINES LOCATED IN BUSHFIRE PRONE AREAS OR BUSHFIRE ABATEMENT ZONES;
 - BRANCHES MUST NOT OVERHANG IN " NO TREE ZONE" AND THE AERIAL LINES MUST BE CLEAR TO SKY.
 - VEGETATION AND HEAVY FUEL MATERIALS MUST BE SUFFICIENTLY CLEAR OF POLES TO PERMIT INSPECTION AND LIMIT DAMAGE DURING BUSHFIRE.
 - MINIMUM CLEARANCE OF 3m MUST BE MAINTAINED AROUND THE POLE IN ALL DIRECTIONS AND TO BE CONSIDERED AS NO TREE ZONE.
- ALL PRUNING MUST COMPLY WITH AS4373 PRUNING OF AMENITY TREE STANDARD.
- WELL MAINTAINED GRASS AND SHRUBS UP TO 1m HEIGHT ARE ALLOWED IN NO TREE ZONE.

| | | | | | | | | | | |
|---|----------|-------------------|----------|----------------------|----------------------|------------------|------------|--------------|------------------|-----------|
| | | Drawn: K. Vedanti | | Designed: K. Vedanti | | evoenergy | | Scale: N.T.S | Date: 28/06/2022 | Sheet No: |
| A STATUS UPDATED - KV | | 10/10/2022 | N. Azizi | W. Cleland | Checked: N. Azizi | | | 29/06/2022 | Work Pack No: | File: |
| B OVERHANG DETAILS AMENDED IN TABLE - KV | | 16/11/2022 | N. Azizi | W. Cleland | Approved: W. Cleland | | 29/06/2022 | | Status: Current | |
| No | Revision | Date | Checked | Approved | Project No: | | A3 | | 3811-021 | |
| The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy. 2018. | | | | | | | | | | Rev B |