



**NOTE**

EQUIPMENT SUPPORT BRACKET TO BE HOT DIP GALVANISED AFTER FABRICATION.  
 THE LENGTH OF THE SUPPORT BRACKET IS DETERMINED BY THE TRENCH WIDTH REQUESTED BY EVOENERGY.

BRACKETS REQUIRED PER EQUIPMENT	
EQUIPMENT	QUANTITY
HV RING MAIN UNIT	2 PER UNIT
LV BOARD	2 PER BOARD
LV BOARD (ACB)	2 PER ACB

REFER TO DRAWING  
 No 4931-01  
 FOR TRENCH DETAILS

**NOT TO SCALE**

E	LOGO AND REFERENCES UPDATED	18/03/2018	B. Suthar	W. Ibrahim	The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy. 2018.
D	SPELLING MISTAKE CORRECTED	22/02/2010	AC	A-NNR	
C	LOGO UPDATE	26/03/2008	AC	GA	
No	Revision	Date	Checked	Approved	ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2018.

 <b>STANDARD SUBSTATION          EQUIPMENT SUPPORT          BRACKET AND          TRENCH EDGE FRAMING</b>		Drawn:	S.Read	Date:	10/05/1995	
		Designed:	E. Amaratunga			
		Checked:	M. Charlton			
		Approved:				
Project No:	Status: Current	A4	4931-02	REV	E	
Work Pack No:	File:					