



NOTES:

- 1) SEALABLE EVOENERGY NEUTRAL LINK (SUPPLIED BY CUSTOMER)
- 2) M.E.N TO BE LOCATED BEHIND METER PANEL
- 3) NO CUSTOMER SUB CIRCUIT SWITCHBOARDS TO BE INSTALLED ON PANEL
- 4) LEAVE 20mm AROUND EDGE OF PANEL AS FREE SPACE
- 5) IT IS ESSENTIAL THAT THE OPENING AND CLOSING OF THE METER PANEL DOES NOT TRANSFER ANY MECHANICAL STRESS OR MOVEMENT TO THE TERMINATION OF THE SERVICE CABLE OR CONSUMER MAINS (PARTICULARLY THE NEUTRAL)
THEREFORE; ALL SERVICE CABLES AND CONSUMER MAINS MUST BE SECURED TO THE METER PANEL. INSULATED CLAMPS, CLIPS OR CABLE TIES AND CABLE TIE MOUNTS CAN BE USED TO SECURE THE CABLES. PLEASE NOTE THAT CLAMPS, CLIPS AND CABLE TIE MOUNTS MUST BE ATTACHED TO THE PANEL WITH FASTENERS, SELF-ADHESIVE PRODUCTS ARE NOT ACCEPTABLE.
- 6) TERMINAL SCREWS OF THE NEUTRAL LINK SHALL BE ACCESSIBLE WITHOUT REMOVAL OF OTHER ASSETS i.e. SERVICE FUSES, METER.
- 7) ALL DIMENSIONS ARE IN MILLIMETRES.

LEGEND

- NETWORK AREA
- CUSTOMER AREA (METERING EQUIPMENT AND DISTRIBUTION BOARD)

**SWITCHBOARD
FRONT VIEW**

(SHOWN WITH EXTERIOR DOOR REMOVED)

		Drawn: P. Sanguinetti		Designed:		evoenergy		Scale:	Date:	Sheet No:	
C	LOGO AND REFERENCES UPDATED TO EVOENERGY	8/01/2018	C. Desai	W. Ibrahim	Checked: P. Sanguinetti	31/07/2013	DUAL TENANCY SWITCHBOARD LAYOUT FOR 600 x 600 POE/METER BOX		Work Pack No:	File:	1/1
B	UPDATED FOR POWER OF CHOICE REFORMS	2/11/2017	C. Desai	W. Ibrahim	Approved: P. Sanguinetti	31/07/2013			Status: Current		
A	NOTE 6 ADDED	18/07/2016	C. Desai	W. Ibrahim	Project No:				A3	8911-326	Rev C
No	Revision	Date	Checked	Approved	ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2017.						