



**NOTES:**

- THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH EVOENERGY SERVICE AND INSTALLATION RULES AND EVOENERGY DRAWING 8912-02 "UNDERGROUND SERVICE CONDUIT REQUIREMENTS". REFER EVOENERGY CONDUIT TECHNICAL STANDARDS P007107.
- AS PART OF THE SHARED TRENCH, A SERVICE CABLE HAS BEEN DIRECTED TO EACH BLOCK AND IS 1000mm INSIDE THE FRONT BOUNDARY AND 850MM BELOW NORMAL GROUND LINE. THIS AREA IS TO REMAIN CLEAR OF OBSTRUCTIONS AND SHOULD NOT BE CONCRETED OR PAVED AS EVOENERGY REQUIRES EXCAVATION ACCESS FOR THE CABLE JOINT THAT WILL BE INSTALLED.
- THE CONDUIT SHALL ENTER THE POE/METER BOX AS TYPICALLY INDICATED ON DRAWING 8912-02.
- THE CONDUIT FROM THE METER BOX SHALL END 1000mm INSIDE THE PROPERTY BOUNDARY.
- A MARKER PEG SHALL BE PROVIDED TO INDICATE THE END OF THE CONDUIT.
- ALL DIMENSIONS ARE IN MILLIMETRES.
- DO NOT SCALE FROM DRAWING.

G	NOTE 1 & DRAINPIPE DETAILS AMENDED	10/04/2013	EA	BS	Drawn:	Designed: A-NNR
H	UPDATED FOR POWER OF CHOICE REFORMS	2/11/2017	C. Desai	W. Ibrahim	Checked:	
I	LOGO AND REFERENCES UPDATED TO EVOENERGY	8/01/2018	C. Desai	W. Ibrahim	Approved: D. HOWE 22-3-99	
J	STANDARD NUMBER UPDATED	7/12/2020	N. Azizi	W. Cleland	Project No:	
No	Revision	Date	Checked	Approved		

The information contained within this drawing & associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Evoenergy. 2017.

ACT Cadastral information supplied by the ACT Environment & Sustainable Development Directorate. © ACT Gov. 2017.

**evoenergy**

TYPICAL UG & OH SERVICE CABLE CONDUIT REQUIREMENTS FOR SINGLE DOMESTIC OR COMMERCIAL INSTALLATION

Scale: 16/03/1999  
Date: 16/03/1999  
Work Pack No:  
File:  
Status: Current

**A3** 8912-03 Rev J