



ITEM	UA TYPE	DESCRIPTION	STOCK CODE	QTY	DRAWING NO
1	P	EARTHING ROD, dia 13 x 1440mm, COPPER CLAD STEEL, EXTENDABLE, NO CLIP	1161222	4	D110-0001
2	P	CONDUCTOR, AERIAL, HD8C, 70mm ² , 19/2.14 (19/083)	1068830	20m	D102-0005
3	P	LUG, SHEAR-BOLT, 25-95mm ² , M13 BOLT HOLE, TINNED ALUMINIUM	1193219	10	D103-0022
4	P	CABLE, BUILDING, 70mm ² , 1C, 19/2.14, 0.6/1kV, V-75, BLACK, PVC INSULATED	1069603	6m	D102-0012
5	P	LABEL, EARTHING, GRADING RING FOR EARTHING CONDUCTORS, 90 x 10.5mm, S/STEEL	1202086	2	D107-0017
6	P	LABEL, EARTHING, HV EARTH GRID FOR EARTHING CONDUCTORS, 90 x 10.5mm, S/STEEL	1202097	4	D107-0018
7	P	LABEL, EARTHING, CMEN BOND FOR EARTHING CONDUCTORS, 90 x 10.5mm, S/STEEL	1202108	1	D107-0019
8	P	CABLE TIE FOR EARTHING CONDUCTOR LABELS 4.6 x 200mm S/STEEL GR316	1202042	14	D107-0027
9	P	LABEL, EARTHING, PADMOUNT, SUBSTATION EARTHING TYPE, CMEN EARTHED	1202207	2	D107-0029
10	I	INTERFACE, EARTHING PARTS, CONNECTIONS, CONNECTORS AND ACCESSORIES	SELECT	10	D199-0001

B	IMAGE UPDATED	JJP	WNI	
C	DEPICTION AND NOTES AMENDED	BAN	WJC	14/11/2019
D	SM1138 REPLACED WITH PO07127 IN NOTE 10 - KV	NAA	WJC	29/07/2022
E	EARTH STOCK CODE UPDATE	JJP	WJC	17/11/2023

evoenergy

The information contained within this drawing and associated electronic file shall remain the property of Evoenergy and shall not be copied or used for any other purpose without express written permission from Evoenergy. © Copyright Evoenergy 2018.

Drawn: M. Barrett Designed: J. Primmer Checked: J. Primmer 12/12/2014 Branch Engineer: W. Cleland 12/12/2014 Branch Manager: Old Drawing No. and Revision:	STANDARD CONSTRUCTION, DISTRIBUTION UNDERGROUND, STATIONS, SA, EARTHING, CMEN EARTHING WITH GRID PADMOUNT SUBSTATION
---	---

Scale: 1:25	Date: 28/11/2014	Sheet No.: 1/1
Project No.:	Stock Code:	
Status: Current		
A1	D303-0012	Rev E